

Town of Holly Springs Public Utilities Department Annual Wastewater System Performance Report

The Town of Holly Springs' Public Utilities Department is pleased to present the Annual Wastewater Quality Report. This report covers the calendar year July 1, 2012 to June 30, 2013. The report summarizes the performance of the treatment plant and identifies the extent to which any terms of its permit, federal laws, state laws, regulations or rules related to the protection of water quality have been violated.

In accordance with House Bill 1160 of the Clean Water Act of 1999, the owner and/or operator of any wastewater treatment works or wastewater collection system that treats or collects primarily domestic or municipal wastes must provide an annual report that summarizes the treatment works or collection system performance over a 12 month period to its users or customers and to the North Carolina Department of Environment and Natural Resources.

The following are definitions of key words used throughout this report provided to help you better understand the performance report:

WRF- Water Reclamation Facility, a facility for the treatment of wastewaters.

Effluent- Partially or completely treated wastewater or other liquid, flowing from a reservoir, basin, treatment process or treatment plant.

ORC – Operator in Responsible Charge

MG - Million gallons

MGD - Million gallons per day


Town of Holly Springs Utley Creek Water Reclamation Facility, Permit # NC0063096 Terry R. Foster, Operator in Responsible Charge

The Town of Holly Springs is permitted to operate a 2.4 MGD water reclamation facility. The facility is designed with a treatment capacity of 6 MGD and is manned 24 hours a day. The treatment process utilizes the activated sludge process that also performs biological nutrient removal of phosphorus and nitrogen. The Holly Springs Water Reclamation Facility (WRF) discharges into Utley Creek which is in the Cape Fear River Basin. The WRF treated 554 MG, and discharged 489 MG of treated effluent to Utley Creek and reclaimed 65 MG for non-potable use in the Town this calendar year.

During the calendar year July 1, 2012 to June 30, 2012 the facility was compliant with federal and state laws, regulations or rules related to the protection of water quality.

If you would like information concerning the Town's wastewater treatment systems please contact the staff of the Public Utilities Department (see information below). This report will not be mailed. A copy of this report can be obtained by visiting the Town Hall at 128 South Main Street between the hours of 8:00 a.m. – 5:00 p.m., Monday through Friday, or you can review the report online at www.hollyspringsnc.us

Respectfully,

A handwritten signature in black ink, appearing to read "Terry R. Foster". The signature is fluid and cursive, with the first name being the most prominent.

Terry R. Foster
Town of Holly Springs
O.R.C.; Chief Operator
(919) 567-4738